



Public Drinking Water Violation Report

Operators are to complete this form to report violations in public drinking water treatment at facilities that provide treatment for surface water or groundwater under the direct influence of surface water. This form is not to be used to report to the public.

System Information

Public Water System Name: City of Rose City

PWS ID #: 1810139

Treatment Plant Name or Number: 15009

Operator Name: Tracy Butcher

Operator Signature: _____

Date Signed: 9/11/24

Operator Telephone Number.: 281-831-9156

Violation Information

Type of Violation(s): *5.0% of turbidity Readings above acceptable level (e.g., turbidity above 5.0 NTU, turbidity between 1.0 NTU and 5.0 NTU, turbidity above 0.3 NTU, low CT value, low residual leaving the plant, low distribution system residual, ClO2 residual above 0.8 mg/L, in distribution, failed to achieve Crypto credit required, etc.)*

Date/Time that the violation was detected: August 2024

Duration of the Violation (if known)

Other Data, for SWTPs only

Finished Water Turbidity

Highest IFE Turbidity Level

Giardia Inactivation (log) [DURING THE EVENT]: =Montg Avg = 209.57

Viral Inactivation (log) [DURING THE EVENT]= Month Avg = 8180.57

Submit Completed Form

Please note that email often is the fastest, most reliable method of communicating a violation.

- Email to: SWTR@tceq.texas.gov
- Mail to: SWTR Coordinator, MC-155, PO BOX 13087, Austin, TX 78711
- Fax to: TCEQ, Water Supply Division 512-239-6050

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: NON-ACUTE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The City of Rose City, PWS ID TX1810139, failed to meet the minimum treatment technique requirements for the month of **August/2024**. Specifically, our water system had more than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.

The City of Rose is currently in process of replacing the filter media to assist in the reduction of the higher turbidity that is occurring at this time.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Tracy Butcher at

1-281-831-9156_____.

Posted /Delivered on: 9/13/2024_____

Instructions for preparing the required Public Notice:

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than [30 days] after the violation was identified. All notifications require the attached Certificate of Delivery due ten days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.



Texas Commission on Environmental Quality
Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS: [TIER II]

Public Water System (PWS) name: PWS NAME
PWS ID (7-digit number required): TXXXXXXXXX
Type of violation: Treatment Technique Violation
Monitoring Period of violation: MONTH / YEAR

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

[Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and]

[Continuous posting or direct delivery as required by 30 TAC §290.122 for non-community water systems; and]

Make an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (Check all below that apply):

- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- Posting the PN in public places
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- Email notification
- Posting the PN on the internet at www._____

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122.

Date of Delivery to Customers _____

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.”

Certified by: Name (print): _____	Title: _____
Phone: _____	Email: _____
Signature: _____	Date Signed: _____

Mail a copy of this completed form and a copy of the Public Notice that was delivered to your customers to:

TCEQ - Drinking Water Inventory & Enforcement Team
Attn: Public Notice (MC-155)
P. O. Box 13087
Austin, TX 78711-3087