

City of Rose City

2024 Drinking Water Quality Report

DEAR CUSTOMER:

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The sources of drinking water (both tap water and bottled water) generally include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791). Contaminants that may be present in the source water include:

1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. 2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. 3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. 4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems. 5) Radioactive contaminants, which can be naturally- occurring or be the result of oil and gas production and mining production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the district's operator, Inframark.

You may be more vulnerable than the general population to certain microbial contaminants such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV / AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from you physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The source of water used by City of Rose City is surface water from the Sabine River Authority Terminal Reservoir

No Source Water Assessment for your drinking water source(s) has been conducted by the TCEQ for your water system. The report describes the susceptibility and the types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information in this assessment allows us to focus our source water protection strategies. For more information on source water assessments and protection efforts at our system contact Starlite Cosek, Inframark, at (409-779-2128).

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following: <http://www.tceq.texas.gov/gis/swaview>

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWWW/>

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water. The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices.

Public input concerning the water system may be made at regularly scheduled meetings, generally held the 2nd Thursday of each month at 6:00 PM at City Hall, 370 S. Rose City Drive, Vidor, TX 77662. You may also contact Starlite Cosek, Inframark, at 409-779-2128 with any concerns or questions you may have regarding this report.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español favor de llamar al tel. (409) 769-6809.

City of Rose City has completed an inventory of our water service lines and determined that our water system does not have any lead, galvanized requiring replacement, or unknown service lines. We achieved this determination after performing visual inspections of the service lines throughout our system.

Definitions & Abbreviations:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

AVG: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 assessment: Study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 assessment: Very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL: Million Fibers per Liter (a measure of asbestos).

Mrem: millirems per year (a measure of radiation absorbed by the body).

N/A: Not applicable.

NTU: Nephelometric Turbidity Units (a measure of turbidity).

pCi/L: Picocuries per liter (a measure of radioactivity).

ppb: micrograms per liter or parts per billion.

ppm: milligrams per liter or parts per million.

ppq: Parts per quadrillion, or picograms per liter (pg/L).

ppt: Parts per trillion, or nanograms per liter (ng/L).

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Substance	Unit of Measure	Year	MCL	Average Level Detected	Min - Max Level Detected	MCLG	In Compliance	Typical Sources
-----------	-----------------	------	-----	------------------------	--------------------------	------	---------------	-----------------

Synthetic Organic Contaminants Including Pesticides and Herbicides

Dalapon	ppb	2024	200	2.97	1.7 – 4.4	200	Yes	Runoff from herbicide used on rights of way
---------	-----	------	-----	------	-----------	-----	-----	---

Unregulated Contaminants

Bromodichloromethane	ppb	2024	N/A	20.0	20 - 20	N/A	Yes	By-product of drinking water disinfection.
Chloroform	ppb	2024	N/A	136.0	136 - 136	N/A	Yes	By-product of drinking water disinfection.
Dibromochloromethane	ppb	2024	N/A	2.8	2.8 - 2.8	N/A	Yes	By-product of drinking water disinfection.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Inorganic Contaminants (Regulated at the Water Plant)

Barium	ppm	2024	2	0.05	0.05 - 0.05	2	Yes	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
--------	-----	------	---	------	-------------	---	-----	---

Turbidity

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest single measurement	2.67 NTU	1 NTU	Yes	Soil runoff.
Lowest monthly % meeting limit	13%	0.3 NTU	Yes	Soil runoff.

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Disinfectant Byproducts

Haloacetic Acids (HAA5)	ppb	2024	60	137.04	74.5 - 208	N/A	No	By-product of drinking water disinfection.
Total Trihalomethanes	ppb	2024	80	195.09	89.7 - 290	N/A	No	By-product of drinking water disinfection.

Health Effects: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Substance	Unit of Measure	Year	MRDL	Average Level Detected	Min - Max Level Detected	MRDLG	In Compliance	Typical Sources
-----------	-----------------	------	------	------------------------	--------------------------	-------	---------------	-----------------

Maximum Residual Disinfectant Level

Chlorine Residual	ppm	2024	4.0	3.4	0.3 – 6.5	4.0	No	Water additive used to control microbes.
-------------------	-----	------	-----	-----	-----------	-----	----	--

Substance	Unit of Measure	Year	90th % Value	EPA Action Level	Results above Action Level	MCLG	In Compliance	Typical Sources
-----------	-----------------	------	--------------	------------------	----------------------------	------	---------------	-----------------

Lead and Copper (Regulated at Customers Tap)

Copper	ppm	2024	0.066	1.3	0	1.3	Yes	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives.
Lead	ppb	2024	0.604	15	0	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Violation	
Violation Type	Duration
HALOACETIC ACIDS (HAA5) - MCL, LRAA	01/01/2024 – 12/31/2024
Health Effects	
Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.	
Explanation	
Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.	
Steps to Correct	
The City of Rose City is currently in the process of converting the current disinfection process from Free Chlorine to a Chloramines based which should help reduce the volatile organic compounds that currently occurs with free chlorine. The City has already been given TCEQ approval to move forward with the Chloramines process, in which involved engineering of new feed points, construction and replacement of the filter media.	

Violation	
Violation Type	Duration
INTERIM ENHANCED SWTR - MONITORING, ROUTINE (IESWTR/LT1), MAJOR	08/01/2024 – 08/31/2024
Health Effects	
The Interim Enhanced Surface Water Treatment Rule improves control of microbial contaminants, particularly Cryptosporidium, in systems using surface water, or ground water under the direct influence of surface water. The rule builds upon the treatment technique requirements of the Surface Water Treatment Rule.	
Explanation	
We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.	
Steps to Correct	
The process for this monitoring has been reviewed and corrective actions have been taken to ensure this does not happen in the future.	

Violation	
Violation Type	Duration
INTERIM ENHANCED SWTR - MONTHLY COMB FLTR EFFLUENT (IESWTR/LT1)	01/01/2024 – 01/31/2024, 03/01/2024 – 12/31/2024
Health Effects	
The Interim Enhanced Surface Water Treatment Rule improves control of microbial contaminants, particularly Cryptosporidium, in systems using surface water, or ground water under the direct influence of surface water. The rule builds upon the treatment technique requirements of the Surface Water Treatment Rule.	
Explanation	
Turbidity levels, though relatively low, exceeded a standard for the month indicated. Turbidity (cloudiness) levels are used to measure effective filtration of drinking water.	
Steps to Correct	
The City of Rose City is in the process of replacing the current filter media to increase turbidity reduction.	

Violation	
Violation Type	Duration
INTERIM ENHANCED SWTR - SINGLE COMB FLTR EFFLUENT (IESWTR/LT1)	01/01/2024 – 01/31/2024, 04/01/2024 – 04/30/2024, 12/01/2024 – 12/31/2024
Health Effects	
The Interim Enhanced Surface Water Treatment Rule improves control of microbial contaminants, particularly Cryptosporidium, in systems using surface water, or ground water under the direct influence of surface water. The rule builds upon the treatment technique requirements of the Surface Water Treatment Rule.	

Explanation
One turbidity measurement exceeded a standard for the month indicated. Turbidity (cloudiness) levels are used to measure effective filtration of drinking water.
Steps to Correct
The City of Rose City is in the process of replacing the current filter media to increase turbidity reduction.

Violation	
Violation Type	Duration
PUBLIC NOTIFICATION RULE LINKED TO VIOLATION	11/17/2022 – 09/13/2024
Health Effects	
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).	
Explanation	
We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.	
Steps to Correct	
Public notices have been prepared and sent out, bringing the system back into compliance.	

Violation	
Violation Type	Duration
PUBLIC NOTICE LINKED NOT LINKED TO VIOLATION	02/16/2024 – 09/06/2024
Health Effects	
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).	
Explanation	
We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.	
Steps to Correct	
Public notices have been prepared and sent out, bringing the system back into compliance	

Violation	
Violation Type	Duration
SURFACE WATER TREATMENT RULE (SWTR) - MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	01/01/2023 – 01/31/2024, 08/01/2024 – 08/31/2024, 12/01/2024 – 12/31/2024
Health Effects	
The Surface Water Treatment Rule seeks to prevent waterborne diseases caused by viruses, Legionella, and Giardia lamblia. The rule requires that water systems filter and disinfect water from surface water sources to reduce the occurrence of unsafe levels of these microbes.	
Explanation	
We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.	
Steps to Correct	
The process for this monitoring has been reviewed and corrective actions have been taken to ensure this does not happen in the future.	

Violation	
Violation Type	Duration
TOTAL TRIHALOMETHANES (TTHM) – MCL, LRAA	12/01/2024 – 12/31/2024
Health Effects	
Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.	
Explanation	
Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.	
Steps to Correct	
The City of Rose City is currently in the process of converting the current disinfection process from Free Chlorine to a Chloramines based which should help reduce the volatile organic compounds that currently occurs with free chlorine. The City has already been given TCEQ approval to move forward with the Chloramines process, in which involved engineering of new feed points, construction and replacement of the filter media.	