



Texas Commission on Environmental Quality

Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS) name: **CITY OF ROSE CITY**
PWS ID (7-digit number required): **TX1810139**
Type of violation: **Treatment Technique Violation**
Time Period of violation: **SEPTEMBER 2024**

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2XA) for community water systems; and

Make an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- XXX Posting the PN in public places
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- XXX Email notification
- Posting the PN on the Internet at www. -----

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122.

Date of Delivery to Customers: 1/10/2025

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Name (print): Tracy Butcher Title: Project Manager
Phone: 281-831-9156
Signature: *Tracy Butcher* Date Signed: 1/10/2025

Mail a copy of this completed form and a copy of the Public Notice that was delivered to your customer: to:

TCEQ - Drinking Water Inventory & Protection Team
Attn: Public Notice (MC-155)
P. O. Box 13087
Austin, TX 78711-3087

Mandatory Language for Surface Water Treatment Technique Violation


SURFACE WATER TREATMENT TECHNIQUE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The CITY OF ROSE CITY, PWS ID TX1810139, failed to meet the minimum treatment technique requirements for the month of **December 2024**. Specifically, our water system had More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month, **December the 8th 2024** the water system recorded 1.0 NTU on the combined filter effluent, and additionally the water system failed to collect Dist. chlorine residual 2 days this month.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact: Kathleen Campbell 979-236-1857
Posted /Delivered on: 1/10/2025



Tracy Butcher 1/10/2025